

500484B5




#### **PROJECT**

**TYPE** 

**NOTES** 

QUANTITY

DATE










Ceiling suspended luminaire made from aluminium; surface Black Matt; powder coated; matt texture; RAL 9005; opal PMMA cover; PCB 3-step binning; phase-cut dim; light colour 3000 K; binning initial MacAdam  $\leq$  3 SDCM; CRI  $\geq$  90; 220 - 240 V; degree of protection IP20; Class 1; light source replaceable by Wever & Ducré or by a professional with explicit authorization;



#### **GENERAL**

Ceiling
Suspended
Black Matt
RAL 9005 <sup>a</sup>
IP20
Interior
1110 lm
CIE flux code: 48 80 96 100
100

## LED

3000 K	
CRI ≥ 90	
L80 / 50000h	
initial MacAdam ≤ 3 SDCM	

#### OPTICAL

Opal

## **ELECTRICAL**


phase-cut dim	
220 - 240 V	_
system 19.5 W	_
Class 1	_

### **PHYSICAL**

length 1314 mm
width 30 mm
height 80 mm
2 kg
cable length 2000 mm

<sup>&</sup>lt;sup>a</sup> Colour may deviate slightly due to production conditions.

### LIGHT DISTRIBUTION





# 500484B5



### **Maintenance Factor**

LLMF 0.98	0.95	0.92	0.89	0.86
LSF 1	1	1	1	1

MF	LMF × RSMF × LLMF × LSF	RSMF <sup>a</sup>	Room Surface Maintenance Factor
MF	Maintenance Factor	LLMF	Lamp Lumens Maintenance Factor
LMF <sup>a</sup>	Luminaire Maintenance Factor	LSF	Lamp Survival Factor

<sup>&</sup>lt;sup>a</sup>According to "CIE 97, Maintenance of indoor electric lighting systems", 2005, ISBN 3-900-734-34-8. The values must be determined by the planner.